



District Level Water Quality Testing and Monitoring Laboratory

Uttarakhand Jal Sansthan, Bageshwar

Ph (OFFICE): 05963-220038, E-mail: eeujsbgr@gmail.com

TEST REPORT

Name and Address of Organization/ Customer	Atal Utkrisht Government Inter College Supi, Bageshwar		
Test Report ID	81/UJS/DLWQTML/2025-26	Reporting Date	21/04/2026
URL No.	TC1323425000000081F		
Date and Time of Sample Received:	20/04/26 & 11:25 PM	Sample Location	Supi
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2025-81	Duration of Analysis	20/04/2026 to 21/04/2026

SN	Parameters	Test Method	Result	Requirement (Acceptable Limit) As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
(A) Organoleptic and Physical Parameters					
1.	pH at 25°C	IS 3025 (Part 11)	7.02	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L	IS 3025 (Part 16)	64	500 Max	2000 Max
3.	Turbidity, NTU	IS 3025 (Part 10)	0.59	1 Max	5 Max
4.	Colour, CU	IS 3025 (Part 4)	Less than 05	5 Max	15 Max
5.	Odour	IS 3025 (Part 5)	Agreeable	Agreeable	Agreeable
(B) General Parameters Concerning Substances					
6.	Total Alkalinity (as CaCO ₃), mg/L	IS 3025 (Part 23)	28	200 Max	600 Max
7.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21)	60	200 Max	600 Max
8.	Calcium as Ca, mg/l	IS 3025 (Part 40)	16.8	75 Max	200 Max
9.	Chloride as Cl, mg/L	IS 3025 (Part 32)	15	250 Max	1000 Max
10.	Magnesium as Mg, mg/l	APHA 24 th Ed- 3500-Mg Method B: 2023 (Calculation Method)	4.4	30 Max	100 Max

Note:-

1. The results listed refer only to tested sample and applicable parameters
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer.

**** End of Report****

Review and Authorized By
(Er. K. S. Pant)
Technical Manager Lab





District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Bageshwar

Ph (OFFICE): 05963-220038, E-mail: eeujsbgr@gmail.com

TEST REPORT

Name and Address of Organization/ Customer	Atal Utkrisht Government Inter College Supi, Bageshwar		
Test Report ID	81-B /UJS/DLWQTML/2025-26	Reporting Date	21/04/2026
URL No.	TC1323425000000081F		
Date and Time of Sample Received:	20/04/26 & 11:25 PM	Sample Location	Supi
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2025-81	Duration of Analysis	20/04/2026 to 21/04/2026

Bacteriological Parameters

SN	Water Quality Parameters Under Biological Scope	Results	Desirable Limit (BIS)	Permissible Limit(BIS) In the Absence of alternative source	Std. Test Method
1	Total Coliform, MPN/100ML	Absent	Absent	Absent	APHA 23rd Ed.-9223 B
2	E- Coli , MPN/100ML	Absent	Absent	Absent	APHA 23rd Ed.-9223.B



(E. K. Pant)
Technical manager lab

